



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00553

OWNER'S NAME: NASH

DATE: 3/21/2016

TYPE: Framing

TIME STARTED: 12:24 PM

INSPECTOR: Amber Green

MAP NUMBER: 20-15-29050-0041

	1. Supply is still not on test. Never signed off.
	2. Mechanical is not complete. Complete fireplace installation.
	3. Not confident electrical installation is complete.

INSTRUCTIONS: Plumbing and mechanical inspection must be inspected and approved prior to framing inspection. Complete above, re-call inspection.

NEXT INSPECTION: Plumbing and Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506