



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00553

OWNER'S NAME: NASH

DATE: 3/24/2016

TYPE: Rough-in plumbing

TIME STARTED: 12:17 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29050-0041

1. Supply @ 70#/15 mins - Ok
2. Plumbing Rough In Ok
3. Mechanical Ok
4. Complete pressure relief valve installation on water heater
5. Soffits Ok (clips verified)

INSTRUCTIONS: Verify corrections @ next inspection

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506