



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00553

OWNER'S NAME: NASH

DATE: 3/25/2016

TYPE: Re-inspection

TIME STARTED: 11:56 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29050-0041

1. Stamped truss sheets not on site
2. Header missing per plan at master bed entry door
3. Electrical not passed yet
4. Fireplace will be seen before cover

INSTRUCTIONS: Do not insulate until electrical is passed

NEXT INSPECTION: Insulation/corrections/trusses/ fireplace

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506