



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00560

OWNER'S NAME: MYERS

DATE: 9/15/2015

TYPE: Footings

TIME STARTED: 2:55 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-10030-0013

	1. Setbacks OK.
	2. Footings OK.
	3. Covered Porch Pier Footings Not Seen. Do Not Pour Porch Footings Prior to Rebar Inspection.

INSTRUCTIONS: OK to Pour Footings Besides Porch.

NEXT INSPECTION: Foundation Walls.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506