



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00564

OWNER'S NAME: VAN TILBURG

DATE: 5/3/2016

TYPE: Insulation

TIME STARTED: 11:24 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 21-14-09058-0004

1. Insulation ok
2. Egress windows ok
3. Remove can lights from garage lid separation or provide approved Fire Rated lights
4. Windows at top of stairs require fall protection. See printout

INSTRUCTIONS: Ok to cover. Address can lights in garage ceiling

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506