



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00607

OWNER'S NAME: CASCADE VIEW INC

DATE: 9/30/2015

TYPE: Slab plumbing

TIME STARTED: 2:33 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-27071-0126

	1. Slab Plumbing OK. DWV Stack Test OK.

INSTRUCTIONS: OK to Backfill

NEXT INSPECTION: Thickened Footings

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremv.haberman@co.kittitas.wa.us](mailto:jeremv.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506