



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00607 OWNER'S NAME: CASCADE VIEW
DATE: 11/4/2015 TYPE: Shearwalls
TIME STARTED: 9:27 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 18-18-27071-0126

	1. Shear Nailing OK.
	2. Holdowns Missing Nuts Throughout. Nuts Installed But Not Tightened.

INSTRUCTIONS: OK to Cover Exterior.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremv.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506