



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00631

OWNER'S NAME: JOHNSON

DATE: 9/30/2015

TYPE: Rough-in plumbing

TIME STARTED: 2:31 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-19-30059-0005

	1. Pluming Rough In OK.
	2. Supply at 80#/15min.
	3. DWV at 8#/15min.

INSTRUCTIONS:

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremv.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506