INSPECTION REPORT

MOI ECHON NEI ON			
PERMIT NUMBER:	BP-15-00706	OWNER'S NAME:	DAKOTA HEIGHTS
DATE:	5/18/2017	TYPE:	Final
TIME STARTED:	10:35 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	19-16-06052-0009		
 Seal penetrations in fire separation Seal void between return and supply duct in garage. Insulate supply ductwork in garage Door to residence to be self closing Install ant-tip bracket at range Complete WUIC final from Fire Marshal Blower door ok Energy credits ok Septic/access ok Post address at site Install louvers in exhaust flappers Crawlspace exceeds 5ft in height and has oversized access through exterior. Crawlspaces intended for storage purposes must have fire protection of floors per IRC 501.3 Remove door and make minimum required size or provide protection per Code 			
NEXT INSPECTION: Re-inspect			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506