

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00788	OWNER'S NAME:	DW FINANCIAL
DATE:	1/21/2016	TYPE:	Final
TIME STARTED:	4:30 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-15-20058-0099		

1. Indoor Fireplace Corrections OK.			
2. Gas Line On Test OK. 40#/15min. OK.			
3. Energy Credits Not Currently Met. Revise Strategy. Provide Documentation,			
4. NOTE: Outdoor Fire Pit Not Complete. Will be Covered on Seperate Permit.			
INSTRUCTIONS:			
NEXT INSPECTION: Final			
RE-INSPECTION FEE DUE? VION YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
ieremv.haberman @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506