INSPECTION REPORT

TYPE:

OWNER'S NAME: MDJ CONTRACTOR

Shearwalls

PERMIT NUMBER: BP-15-00813

11/24/2015

DATE:

TIME STARTED:		11:58 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:		17-18-07060-0007		
	Bottom nailing on south side			
	2. Shearwall C on garage front not per plan. 3" staggered and over header			
	3. Check edge nailing on back of house			
INSTRUCTIONS: complete above				
NEXT INSPECTION: re-inspect				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
iessica.contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •				
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506				