## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00878	OWNER'S NAME:	STRATTON
DATE:	2/16/2017	TYPE:	Rough-in plumbing
TIME STARTED:	3:38 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	16-20-03000-0009		
1. DWV at 5#-ok 2. H20 at 80#-ok			
INSTRUCTIONS:			
NEXT INSPECTION:	Mechanical		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  ADDRESS: <u>iessica.contratto</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506