



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00890

OWNER'S NAME: SENYOHL

DATE: 4/19/2017

TYPE: Insulation

TIME STARTED: 12:07 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-17-35010-0001

1. Wall insulation ok. Foam flash and batt
2. Floor insulation foam flash. Batt not yet installed
3. Vaulted area requires foam spray in due to no ventilation. Not applied yet

INSTRUCTIONS: Call when insulation is complete

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506