INSPECTION REPORT

OWNER'S NAME: WILLETT

PERMIT NUMBER: BP-15-00903

DATE:	4/22/2016	TYPE:	Insulation
TIME STARTED:	11:48 AM	INSPECTOR:	Lou Whitford
MAP NUMBER:	18-20-07000-0036		
1. OK WALL INSULATION R-21			
2. OK CEILING R-39			
3. OK WINDOWS U-VALUE .26			
4. OK TO COVER			
INSTRUCTIONS: REMEMBER TO POST ENERGY COMPLIANCE W/ BLOWER DOOR TEST RESULTS.			
NEXT INSPECTION: FINAL. PROVIDE HEALTH AND PUBLIC WORKS APPROVAL.			
RE-INSPECTION FEE DUE? VES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
lou.whitford @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			