



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00903

OWNER'S NAME: WILLETT

DATE: 1/5/2017

TYPE: Re-inspection

TIME STARTED: 1:22 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-20-07000-0036

1. NOTE: Owner Did Not Leave Contact Phone Number on Inspection Request.
2. RESIDENCE OCCUPIED PRIOR TO APPROVAL OF CERTIFICATE OF OCCUPANCY. UNABLE TO ACCESS STRUCTURE. OWNER NOT AT HOME.
3. Unable to Verify Correction of Prior Violations Documented 12/16/2016.
4. Crawl Space Access Door Not Insulated.
5. Blower Door Test Result Not Provided.
6. Approved Plans Not Onsite.
7. Septic and Access Not Approved.
8. Exposed OSB in Soffits Must Be Sealed and May Not Meet WUIC Requirement.
9. NOTE: Re Fee

INSTRUCTIONS: DO NOT OCCUPY STRUCTURE PRIOR TO CERTIFICATE OF OCCUPANCY BEING APPROVED. MAKE CORRECTIONS ABOVE.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506