



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00909

OWNER'S NAME: KANE

DATE: 4/7/2016

TYPE: Slab plumbing

TIME STARTED: 9:42 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 16-19-28050-0008

1. Hydronics at 100# both sides-ok
2. Slab insulation and vapor barrier ok
3. Thermal break ok

INSTRUCTIONS: Ok to pour

NEXT INSPECTION: Floor framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506