



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00909

OWNER'S NAME: KANE

DATE: 7/8/2016

TYPE: Exterior shear

TIME STARTED: 1:59 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 16-19-28050-0008

1. Floor to floor straps on back side page S2.03, bubbled in blue ink
2. W2 wall at downstairs front bed 2 not nailed sufficiently
3. Complete strap nailing
4. Entry alcove not nailed off. (not shear, but.....)
5. Install A35 clips on top of shearwalls per schedule

INSTRUCTIONS: Complete above, re-inspect

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506