



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00910

OWNER'S NAME: STROLE

DATE: 9/13/2016

TYPE: Mono pour

TIME STARTED: 9:38 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-18-35020-0002

1. NOTE: Access to site is from 2546 Robbins
2. Address & Street must be posted @ Robbins Rd
3. Site Address must be posted
4. Setbacks Ok
5. (1) Horizontal #4 required @ top of stem wall per foundation handout
6. DO NOT POUR

INSTRUCTIONS: DO NOT POUR/Complete corrections

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506