



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00922

OWNER'S NAME: WT DEVELOPMENT

DATE: 2/11/2016

TYPE: Insulation

TIME STARTED: 10:05 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31077-0001

1. Water @ 80#/15 mins - Ok
2. DWV @ 5#/15 mins - Ok
3. Gas @ 30#/15 mins - Ok
4. Rear patio footing correction not complete - verify @ Final
5. Insulation @ range hood correction not complete - verify @ Final
6. Insulation Ok
7. Other Frame/Plumb/Mech corrections Ok
8. Ok to cover

INSTRUCTIONS: Complete corrections above (verify @ Final)/Ok to cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506