



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00945

OWNER'S NAME: BIRD CAPITAL MANAG

DATE: 6/1/2017

TYPE: Footings

TIME STARTED: 12:15 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19051-0031

1. 30x30 Footing @ back of garage not correct size - clouded on dwgs
2. 36x36x12 is not the correct depth and requires (4) #4 EW - clouded on dwgs
3. 42x42x12 is not correct depth and requires (5) #4 EW - clouded on dwgs
4. 24x24 on south wall not correct size - clouded on dwgs
5. Exterior pads not installed
6. DO NOT POUR

INSTRUCTIONS: DO NOT POUR/Make corrections

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506