



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00037

OWNER'S NAME: YOUNG

DATE: 7/26/2016

TYPE: Plumbing

TIME STARTED: 12:06 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-14-02050-0002

1. DWV not on Test - #5/15 mins required by code
2. Supply not on test - 50#/15 mins required per code

INSTRUCTIONS: Put the systems on test/Re-Inspection

NEXT INSPECTION: Re-Inspectoin

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506