



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00068

OWNER'S NAME: WOLFORD

DATE: 5/16/2016

TYPE: Radiant heat

TIME STARTED: 10:40 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-10052-0004

1. ALTERNATE DOOR HEADER ENGINEERING OK.
2. Building Not Permitted for Insulation or Heat. Revision Required.
3. NOTE: R-10 Slab Insulation Verified. Radiant Tubing Test Verified. 100#/15min . OK.

INSTRUCTIONS: OK to Pour Slab.

NEXT INSPECTION: Wall/Attic Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506