



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00114

OWNER'S NAME: JACKSON

DATE: 4/7/2016

TYPE: Exterior shear

TIME STARTED: 1:16 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-18-08058-0006

1. THD50600H concrete screws 8" from ends of G walls in sill plate

INSTRUCTIONS: Ok to cover, see at interior

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506