



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00114

OWNER'S NAME: MDJ CONTRACTORS

DATE: 4/20/2016

TYPE: Plumbing

TIME STARTED: 9:45 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08058-0006

1. Corrections from Shear OK.
2. Plumbing Rough In OK. DWV at 6#/15min. Supply at 70#/15min. OK.
3. NOTE: MEchanical Inspection also Performed.
4. Supply/Return Ducting OK.
5. BAth Exhaust fans not terminated. Will see at Framing.
6. Gas Line Not Installed. Will See at Framing.

INSTRUCTIONS: Complete Above

NEXT INSPECTION: FRaming.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506