INSPECTION REPORT

PERMIT NUMBER:	BP-16-00194	OWNER'S NAME:	NORTHLAND INVESTI
DATE:	6/29/2016	TYPE:	Floor framing
TIME STARTED:	11:24 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-26063-0001		
4 studs in cripple wall missing at point load. Circle in blue on foundation page			
INSTRUCTIONS: add studs, ok to cover			
NEXT INSPECTION: Shearwalls/point load			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
	QUESTIONS? PLEASE CONTACT THE I ADDRESS:j	NSPECTOR AT THE FO essica.contratto @	
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			