INSPECTION REPORT

PERMIT NUMBER:	BP-16-00237	OWNER'S NAME:	SMITH
DATE:	7/28/2016	TYPE:	Mechanical and plumbir
TIME STARTED:	11:47 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	18-17-35051-0002		
1. Gas at 20#-ok 2. DWV at 5#-ok 3. H20 at 75#-ok 4. Mechanical ro			
INSTRUCTIONS:			
NEXT INSPECTION:	Framing		
RE-INSPECTION FEE DUE? VIOLET NO YES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: iessica.contratto @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98920 Wildin Office Line: 509-902-7506			