



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00268

OWNER'S NAME: BARGE

DATE: 8/8/2016

TYPE: Slab plumbing

TIME STARTED: 1:50 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 22-11-15052-0014

1. Underslab DWV on Stack - Ok
2. Supply @ 120#/15 mins - Ok
3. Underslab Plumbing RI Ok
4. Slab Insulation Ok

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506