



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00276

OWNER'S NAME: PAGE

DATE: 6/22/2016

TYPE: Footings

TIME STARTED: 11:03 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-12040-0005

1. Setbacks Ok
2. Footings Ok
3. Ok to pour
4. NOTE: Pump water out of holes prior to pour

INSTRUCTIONS: Pump water out of post holes/When complete Ok to pour

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506