



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00281

OWNER'S NAME: O'BRIEN

DATE: 9/28/2016

TYPE: Rough-in mechanical

TIME STARTED: 5:03 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-14050-0929

1. Gas Line at 15#/15min. OK.
2. Supply/Return OK.
3. Exhaust OK.

INSTRUCTIONS: OK to Call fro Framing Once Electrical is approved.

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506