



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00284

OWNER'S NAME: CURTIS

DATE: 6/10/2016

TYPE: Footings

TIME STARTED: 10:07 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31067-0003

1. Setbacks Ok
2. Mono pour Ok
3. Ok to pour
4. NOTE: Foundation vents not installed
5. NOTE: Crawl space access not installed to existing

INSTRUCTIONS: Ok to pour

NEXT INSPECTION: Floor Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506