INSPECTION REPORT

PERMIT NUMBER:	BP-16-00340	OWNER'S NAME:	KELLEY
DATE:	10/31/2016	TYPE:	Framing
TIME STARTED:	10:19 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	18-17-36051-0007		
1. Gas @ 30#/15 mins - Ok 2. Trusses Ok 3. Add A35's per 3/S4.2 4. Add A35's @ headers per 6/S4.1 5. Complete blocking per details 6 & 8/S4.2 6. Fireplace not installed 7. Add straps to header @ mechanical header			
mornochons. Complete above, on to inicalate, verify confections & inicalaten			
NEXT INSPECTION: Insulation			
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506