



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00340

OWNER'S NAME: KELLEY

DATE: 11/18/2016

TYPE: Stove or fireplace

TIME STARTED: 3:20 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-17-36051-0007

1. Interior Fireplace Rough In OK.
2. Exterior Fireplace Enclosure Requires Draftstop From Attic.

INSTRUCTIONS: OK to Cover Interior Fireplace

NEXT INSPECTION: Exterior Fireplace Rough In.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506