



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00371

OWNER'S NAME: VILKOTSKI

DATE: 7/14/2016

TYPE: Slab plumbing

TIME STARTED: 1:08 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-15-01050-0002

1. Slab Plumbing on Stack - Ok
2. Ok to cover

### INSTRUCTIONS:

NEXT INSPECTION: Slab Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506