INSPECTION REPORT

| PERMIT NUMBER: | BP-16-00374 | OWNER'S NAME: | DK PROFESSIONAL |
|---|------------------|---------------|-----------------|
| DATE: | 6/21/2016 | TYPE: | Footings |
| TIME STARTED: | 2:58 PM | INSPECTOR: | Jeremy Haberman |
| MAP NUMBER: | 20-14-12065-0019 | | |
| Setbacks OK. Footings OK. NOTE:Garage Foundation Walls Not Permitted Over Two Feet Tall Per MAster Plan | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| INSTRUCTIONS: OK to Pour Footings | | | |
| NEXT INSPECTION: | Foundation Walls | | |
| RE-INSPECTION FEE | DUE? NO YES | | \$ |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION | | | |
| QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL | | | |
| ADDRESS: <u>ieremv.haberman</u> @co.kittitas.wa.us | | | |
| INSPECTION REQUEST LINE: 509-962-7694 | | | |

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506