



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00399

OWNER'S NAME: ALTMANN

DATE: 1/13/2017

TYPE: Plumbing

TIME STARTED: 10:20 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-34050-0060

1. Supply @ 45# - Needs to be min 50#/15 mins
2. DWV does not appear to be on test - Needs to be min 5#/15 mins
3. Provide verification of completed special inspection requests for field welds

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506