



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00424

OWNER'S NAME: RIDER

DATE: 8/3/2016

TYPE: Footings

TIME STARTED: 12:50 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-14051-0003

1. NOTE: All Support Posts Must Bear on Footings 12" Wide x 24" Deep.
2. (3) New Posts OK.
3. (6) Existing Posts Must be Excavated and Poured or Verified 12" Wide x 24" Deep.

INSTRUCTIONS: OK to Pour (3) New Posts.

NEXT INSPECTION: Re Inspect Footings

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506