



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00450

OWNER'S NAME: GAGE

DATE: 6/16/2017

TYPE: Rough-in plumbing

TIME STARTED: 10:09 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-04040-0015

1. Supply @ 100#/15 mins - Ok
2. DWV @ 2# - Needs to be 5#/15 mins or stack

INSTRUCTIONS: Test DWV

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506