



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00560

OWNER'S NAME: SMITH

DATE: 10/27/2016

TYPE: Slab

TIME STARTED: 12:11 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-13-11050-0044

1. NOTE: Concrete being poured @ time of inspection
2. One "D" Footing visible and verified Ok
3. Perimeter thickened footing to have (2) horiz #4 wet set
4. Contractor indicated JC approved via photo verification

INSTRUCTIONS:

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506