



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00566

OWNER'S NAME: NEW SUNCADIA LLC

DATE: 10/10/2016

TYPE: Slab plumbing

TIME STARTED: 2:01 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-18040-0003

1. PL 311 @ 30#/15 mins - Ok
2. PL 320 Hot Tub 1st Lift @ 30#/15 mins - Ok
3. Line PL3-20 south (total of 6 lines) not on test

INSTRUCTIONS: Place PL3-20 and 5 other remaining lines on test/Re-Inspect

NEXT INSPECTION: Re-Inspect

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506