



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00566

OWNER'S NAME: NEW SUNCADIA

DATE: 11/21/2016

TYPE: Rough-in plumbing

TIME STARTED: 1:26 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-18040-0003

1. Whirlpool Spa Plumbing OK. Tested to 20#/15min. OK.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506