



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00566 OWNER'S NAME: NEW SUNCADIA
DATE: 12/21/2016 TYPE: Foundation walls
TIME STARTED: 1:41 PM INSPECTOR: Justin Bennett
MAP NUMBER: 20-15-18040-0003

1. Complete 2nd layer of rebar mat for surge tank lid
2. NOTE: Do not pour until approved by special inspector

INSTRUCTIONS: Complete above/Ok to pour once approved by special inspector

NEXT INSPECTION:

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506