



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00578

OWNER'S NAME: FRERKS

DATE: 1/18/2017

TYPE: Exterior shear

TIME STARTED: 4:04 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-17-28063-0007

1. Exterior Shear Nailing OK.
2. Window Added In Shear Wall Not Per Plan. Provide Engineers Approval.
3. HDU's Not Installed Throughout. SST Bolts Verified.

INSTRUCTIONS: OK to Cover Exterior

NEXT INSPECTION: Shear Reinspecion or Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506