



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00578

OWNER'S NAME: FRERKS

DATE: 5/1/2017

TYPE: Rough-in plumbing

TIME STARTED: 11:03 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-17-28063-0007

1. Gas at 17#/15-ok
2. DWV at 5#-ok
3. H2O at 65#-ok
4. Fireplace rough-in ok
5. Supply, return and exhaust duct ok

INSTRUCTIONS: Complete electrical

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506