



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00579

OWNER'S NAME: MCINTURFF

DATE: 12/21/2016

TYPE: Shearwalls

TIME STARTED: 11:01 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12051-0607

1. Tighten up nailing as indicated with red wall marker (3) locations
2. Complete panel edge blocking on west side of garage
3. Complete panel edge blocking in NW corner of house
4. Install galv nails in sill - entire perimeter
5. A35's Ok
6. Floor corrections emailed to JC - confirm
7. HD installation not complete

INSTRUCTIONS: Complete above/Once complete Ok to cover exterior/Verify HD's @ framing/Confirm floor corrections on file

NEXT INSPECTION: Plumb//Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506