



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00579

OWNER'S NAME: MCINTURFF

DATE: 5/17/2017

TYPE: Final

TIME STARTED: 11:46 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12051-0607

1. Septic not approved
2. Garage mandoor not self closing
3. Garage step not code - exceeds 7-3/4"
4. Maintain fire separation @ solar disconnect
5. Fireplace combustion air must come in below fire box
6. Window @ master soaker tub not tempered
7. Insulation Ok
8. Plumbing Ok
9. Blower door Ok
10. Energy Ok - with Solar BP-17-00179

INSTRUCTIONS: Complete above/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506