



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00616

OWNER'S NAME: FORTUNE CREEK

DATE: 2/24/2017

TYPE: Mechanical and plumbir

TIME STARTED: 2:53 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-15-07061-0043

1. MEchanical Supply/Return OK.
2. Mechanical Exhaust OK.
3. Gas Line OK. 100#/15min. OK.
4. Fireplace Rough In OK. Draftstop OK.
5. Plumbing OK/ DWV at 5#/15min. OK. Supply at 80#/15min. OK.

INSTRUCTIONS: OK to Call for Framing Once L&I is Passed.

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506