



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00625

OWNER'S NAME: MERITAGE DEVELOPM

DATE: 11/7/2016

TYPE: Floor framing

TIME STARTED: 11:38 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0088

1. Align point load blocking with post in kitchen

INSTRUCTIONS: Complete above/Once complete Ok to cover

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506