



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00625

OWNER'S NAME: MERITAGE DEVELOPM

DATE: 4/3/2017

TYPE: Rough-in plumbing

TIME STARTED: 12:08 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0088

1. Interior shear not complete - screws are not acceptable
2. HD's not complete - verify next inspection
3. DWV @ 5#/15 mins - Ok
4. Supply @ 25# - must be 50#/15 mins
5. Plumbing nail plates needed throughout
6. Vent in upstairs bathroom to be relocated to allow for insulation

INSTRUCTIONS: Complete above/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506