



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00625

OWNER'S NAME: BARANOWSKI

DATE: 4/5/2017

TYPE: Rough-in plumbing

TIME STARTED: 11:42 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0088

1. Supply @ 75#/15 mins - Ok
2. Nail plates still required in multiple locations - indicated in RED on studs
3. Interior Shear not complete - verify @ framing

INSTRUCTIONS: Complete above/Re-Inspection

NEXT INSPECTION: Re-Inspection/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506