



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00626

OWNER'S NAME: MINERS CAMP

DATE: 7/13/2017

TYPE: Exterior shear

TIME STARTED: 7:29 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-19060-0005

1. Exterior nailing ok
2. 4 straps at garage front to upper shear panels missing
3. Interior shear upstairs not complete. Follow detail on A8 on interior walls to truss. Can be seen later
4. HTT5 hold downs missing at garage separation wall. Can be seen later

INSTRUCTIONS: Complete straps, ok to cover

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506